



# IM2/SensorLab Output Register Direct Overlay UDT

---



# Import UDT

- In TIA Portal, open the Project tree.
- Expand External source files.
- Click Add new external file.
- Browse to the SensorLab overlay UDT source file (for example, UDT\_HEN\_SLS2PLC\_Overlay.udt).
- Click Open to import it into your project.
- Confirm the file now appears under External source files.




# Generate Blocks

- In TIA Portal, open the Project tree.
- Under External source files, right-click the imported UDT source file and select Generate blocks from source.
- Click OK to acknowledge the warning message.
- The usable data type is created and appears in the PLC data types folder.
- Compile the project so the imported UDT is available for use in tag tables and program blocks.



# Create a PLC Tag Table

- In TIA Portal, open the Project tree.
- Expand PLC tags.
- Click Add new tag table.
- Confirm the new tag table appears under the PLC tags folder.
- Right-click the new tag table and select Properties.
- In the Name field, enter a relevant name (e.g., EAF\_SLS).
- Click OK.



# Record Starting SLS Input Address from Device Config


- In Project tree, expand Devices & networks.
- Click the PLC (CPU) node.
- Click Device configuration.
- In the workspace, select the target device/module (e.g., EAF\_SLS) so its details load.
- In the right-hand pane, open the Device overview tab.
- In the Device overview table, find the module row for the SLS I/O module (for example, 100 Word In- and Output\_1).
- Read the I address column on that row. The first value shown is the input start address (68 in this example).
- Record that input start address for the tag / UDT mapping.

The screenshot shows the Siemens SIMATIC Manager interface. The Project tree on the left is expanded to 'SLS FB Library Testing Then Remove' > 'GMOOfficePLC [CPU 1214C DC/...' > 'Device configuration'. The main workspace shows a rack diagram with the 'EAF\_SLS' device. The 'Device overview' table on the right is displayed in 'Device view' mode. The table has the following data:

| Module                    | Rack | Slot | I address | Q address | Type                    |
|---------------------------|------|------|-----------|-----------|-------------------------|
| EAF_SLS                   | 0    | 0    |           |           | EL6631-0010 V2.0        |
| Interface                 | 0    | 0    |           |           | el6631-0010             |
| 100 Word In- and Output_1 | 0    | 1    | 68...267  | 64...263  | 100 Word In- and Output |
|                           | 0    | 2    |           |           |                         |
|                           | 0    | 3    |           |           |                         |
|                           | 0    | 4    |           |           |                         |
|                           | 0    | 5    |           |           |                         |
|                           | 0    | 6    |           |           |                         |
|                           | 0    | 7    |           |           |                         |
|                           | 0    | 8    |           |           |                         |
|                           | 0    | 9    |           |           |                         |
|                           | 0    | 10   |           |           |                         |
|                           | 0    | 11   |           |           |                         |
|                           | 0    | 12   |           |           |                         |
|                           | 0    | 13   |           |           |                         |
|                           | 0    | 14   |           |           |                         |
|                           | 0    | 15   |           |           |                         |
|                           | 0    | 16   |           |           |                         |
|                           | 0    | 17   |           |           |                         |
|                           | 0    | 18   |           |           |                         |
|                           | 0    | 19   |           |           |                         |
|                           | 0    | 20   |           |           |                         |
|                           | 0    | 21   |           |           |                         |


# Add Station 1 Tags to New PLC Tag Table

- In Project tree, expand PLC tags.
- Click the tag table you just created (for example, EAF\_SLS) to open it in the editor.
- In the first empty row, enter a tag Name (example: SLS\_Results\_Sta1).
- In the Data type column, select the imported UDT: udt\_HEN\_SLS2PLC\_Overlay.
- In the Address column, enter the input start address recorded from Device overview (example: %I68.0).
- Press Enter to accept the row.



# Add Station 2 Tags to New PLC Tag Table

- With the EAF\_SLS tag table still open, click the next empty row (Row 2).
- Enter a tag Name (example from screenshot: SLS\_Results\_Sta2).
- In the Data type column, select the imported UDT:
  - udt\_HEN\_SLS2PLC\_Overlay.
- In the Address column, enter the Station 2 start address.
  - By default, TIA Portal auto-fills the next available input address after the previous tag. In this case, that is the correct behavior.
  - In this example, that value is %I132.0.
- Press Enter to accept the row.



# Monitor Data in New PLC Tag Table

- Save the project.
- Compile and download to device.
- Connect to the PLC, then click Go online.
- Open the PLC tag table (for example, PLC tags > EAF\_SLS).
- Expand the first tag (e.g., SLS\_Results\_Sta1) to show its UDT members.
- Enable monitoring (“glasses”) in the tag table and confirm that the fields update as the device sends data.

SLS Base - Document Development Only > GMOOfficePLC [CPU 1214C DC/DC] > PLC tags > EAF\_SLS [2]

| Name                        | Data type                 | Address | Retain | Acces... | Writa... | Visibl... | Monitor value     | Comment  |
|-----------------------------|---------------------------|---------|--------|----------|----------|-----------|-------------------|--|
| 1 SLS_Results_Sta1          | "udt_HEN_SLS2PLC_Overlay" | %I68.0  |        |          |          |           | 16#00             |  |
| 2 Status4                   | Byte                      | %I68    |        |          |          |           | 16#01             |  |
| 3 Status3                   | Byte                      | %I69    |        |          |          |           | 16#4E             | Probe type (4E = 'N' = None) Table 8 in ma...    |
| 4 StartMeasurementViewer    | Bool                      | %I70.0  |        |          |          |           | TRUE              | Status Byte 2.0 - Start Measurement viewer       |
| 5 LinesOpen                 | Bool                      | %I70.1  |        |          |          |           | TRUE              | Status Byte 2.1 - Lines Open                     |
| 6 EndMeasurementViewer      | Bool                      | %I70.2  |        |          |          |           | FALSE             | Status Byte 2.2 - End Measurement viewer         |
| 7 ProbeTypeLevel            | Bool                      | %I70.3  |        |          |          |           | FALSE             | Status Byte 2.3 - Level Probe                    |
| 8 ProbeTypeCeloxSlac        | Bool                      | %I70.4  |        |          |          |           | FALSE             | Status Byte 2.4 - Celox Slac Probe               |
| 9 InsulationWarning         | Bool                      | %I70.5  |        |          |          |           | FALSE             | Status Byte 2.5 - InsulationWarning - Insu...    |
| 10 BlinkingActive           | Bool                      | %I70.6  |        |          |          |           | FALSE             | Status Byte 2.6 - Blinking Active                |
| 11 Horn                     | Bool                      | %I70.7  |        |          |          |           | FALSE             | Status Byte 2.7 - Horn Active                    |
| 12 RedLight                 | Bool                      | %I71.0  |        |          |          |           | FALSE             | Status Byte 1.0 - Red -End of Measurement        |
| 13 YellowLight              | Bool                      | %I71.1  |        |          |          |           | FALSE             | Status Byte 1.1 - Yellow - Measurement Bu...     |
| 14 GreenLight               | Bool                      | %I71.2  |        |          |          |           | FALSE             | Status Byte 1.2 - Green - Probe Detected         |
| 15 MeasurementError         | Bool                      | %I71.3  |        |          |          |           | FALSE             | Status Byte 1.3 - Error Measurement              |
| 16 CarbonMeasurement        | Bool                      | %I71.4  |        |          |          |           | FALSE             | Status Byte 1.4 - Carbon Measurement             |
| 17 BathLevelMeasurement     | Bool                      | %I71.5  |        |          |          |           | FALSE             | Status Byte 1.5 - Bath Level Measurement         |
| 18 CeloxMeasurement         | Bool                      | %I71.6  |        |          |          |           | FALSE             | Status Byte 1.6 - Celox(EMF) Measurement         |
| 19 TDxComplete              | Bool                      | %I71.7  |        |          |          |           | FALSE             | Status Byte 1.7 - TDx                            |
| 20 ERR_NoCTemp              | Bool                      | %I72.0  |        |          |          |           | FALSE             | Error Byte 4.0 - No Cold Junction                |
| 21 ERR_TCBreak              | Bool                      | %I72.1  |        |          |          |           | FALSE             | Error Byte 4.1 - TC Break                        |
| 22 ERR_Spare_4_2            | Bool                      | %I72.2  |        |          |          |           | FALSE             | Error Byte 4.2 - Spare                           |
| 23 ERR_Spare_4_3            | Bool                      | %I72.3  |        |          |          |           | FALSE             | Error Byte 4.3 - Spare                           |
| 24 ERR_RFLossWhileMeasuring | Bool                      | %I72.4  |        |          |          |           | FALSE             | Error Byte 4.4 - RF Link Wireless broken du...   |
| 25 ERR_RFBadSignal          | Bool                      | %I72.5  |        |          |          |           | FALSE             | Error Byte 4.5 - Bad reception - RF link has ... |
| 26 ERR_NoEvaluation         | Bool                      | %I72.6  |        |          |          |           | FALSE             | Error Byte 4.6 - No evaluation                   |
| 27 ERR_Spare_4_7            | Bool                      | %I72.7  |        |          |          |           | FALSE             | Error Byte 4.7 - Spare                           |
| 28 PlaceID_b3               | Byte                      | %I873   |        |          |          |           | 16#00             | PlaceID or Bath Level depending on dropp...      |
| 29 HeatNumber               | Array[0..7] of Char       | %I74.0  |        |          |          |           | 00                |  |
| 30 UTC_Date_ms              | Date                      | %I82    |        |          |          |           | D#2026-06-16      |  |
| 31 UTC_Time_days            | Time                      | %I84    |        |          |          |           | T# 16H_3M_435_... |  |
| 32 Temperature              | Real                      | %ID88   |        |          |          |           | 3047.415          | Temperature                                      |
| 33 EMF                      | Real                      | %ID92   |        |          |          |           | -180.002          | EMF  |
| 34 aO                       | Real                      | %ID96   |        |          |          |           | 4.684244          | Oxygen PPM                                       |
| 35 Al                       | Real                      | %ID100  |        |          |          |           | 0.09542047        | Aluminum %                                       |
| 36 C                        | Real                      | %ID104  |        |          |          |           | 1.356316E-19      | Carbon %   |
| 37 FeO                      | Real                      | %ID108  |        |          |          |           | 1.356316E-19      | FeO  |
| 38 SampleIndex              | Real                      | %ID112  |        |          |          |           | 2.9               | Sample Index (counter)                           |
| 39 SampleCH0                | Real                      | %ID116  |        |          |          |           | 3046.912          | Sample CH0 (TMF) (with above sample)             |
| 40 SampleCH1                | Real                      | %ID120  |        |          |          |           | -180.0044         | Sample CH1 (EMF) (with above sample)             |
| 41 ResCH0                   | Real                      | %ID124  |        |          |          |           | 2.258703E+08      | Online Resistance CH 0                           |
| 42 ResCH1                   | Real                      | %ID128  |        |          |          |           | 2.180677E+08      | Online Resistance CH 1                           |
| 43 SLS_Results_Sta2         | "udt_HEN_SLS2PLC_Overlay" | %I132.0 |        |          |          |           | 00                |  |
| 44 <Add new>                |                           |         |        |          |          |           |                   |  |